



John R. Kasich, Governor
Mary Taylor, Lt. Governor
Craig W. Butler, Director

Re: Village of McComb WWTP
Notice of Violation
NPDES
Hancock County
2PB00002

August 5, 2014

Mr. Kevin Siferd
Village Administrator
Village of McComb
P. O. Box 340
McComb, Ohio 45858

Dear Mr. Siferd:

A review of the self-monitoring reports that are submitted under the National Permit Discharge Elimination System (NPDES) permit for the Village of McComb wastewater treatment plant (WWTP) shows that this facility is in significant non-compliance (SNC) for Nitrogen, Ammonia, Suspended Solids, Total, and E.coli bacteria at final outfall number 001. I am enclosing a list of violations for this facility for the period of January 1, 2014, through July 1, 2014.

A facility becomes SNC when it exceeds the effluent limit for four or more months in two consecutive quarters or exceeds the effluent limit significantly in any two months in two consecutive quarters. Achieving compliance with Ohio's environmental laws is a primary focus of Ohio EPA in order to reduce risks to public health and welfare.

On March 7, 2014, a Permit to Install (PTI) was issued by this agency for a new 0.388 mgd Oxidation Ditch WWTP to replace inadequate existing facilities. Within 21 days of the date of this letter, please provide us, if available, a proposed construction timetable to install the replacement WWTP. The timetable may also be submitted by email to me at rick.zuzik@epa.ohio.gov.

If you have any questions, please contact me at 419-373-3020, or email at rick.zuzik@epa.ohio.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "R. A. Zuzik". The signature is written over a horizontal line that extends across the page.

Richard A. Zuzik, MSE
Division of Surface Water

/jlm
Enclosure
pc: Ann Scott, IFM
ec: Tracking

Get New Data

Permit No.	Reporting Period	Station	Reporting Code	Parameter	Limit Type	Limit	Reported Value	Violation Date
2PB00002*HD	March 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	11.1	3/1/2014
2PB00002*HD	March 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	3.63	3/15/2014
2PB00002*HD	March 2014	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	5.55375	3/1/2014
2PB00002*HD	March 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	6.095	3/22/2014
2PB00002*HD	April 2014	001	00530	Total Suspended Solids	7D Conc	18.0	20.	4/15/2014
2PB00002*HD	April 2014	001	00530	Total Suspended Solids	30D Conc	12.0	23.46	4/1/2014
2PB00002*HD	April 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	10.3	4/1/2014
2PB00002*HD	April 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	3.0	10.62	4/22/2014
2PB00002*HD	April 2014	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	2.0	6.183	4/1/2014
2PB00002*HD	April 2014	001	80082	CBOD 5 day	7D Conc	15.0	15.5	4/1/2014
2PB00002*HD	April 2014	001	80082	CBOD 5 day	7D Conc	15.0	19.	4/22/2014
2PB00002*HD	April 2014	001	80082	CBOD 5 day	30D Conc	10.0	13.8	4/1/2014
2PB00002*HD	May 2014	001	00530	Total Suspended Solids	7D Conc	18.0	34.	5/1/2014
2PB00002*HD	May 2014	001	00530	Total Suspended Solids	7D Conc	18.0	18.5	5/8/2014
2PB00002*HD	May 2014	001	00530	Total Suspended Solids	30D Conc	12.0	22.625	5/1/2014
2PB00002*HD	May 2014	001	00530	Total Suspended Solids	7D Conc	18.0	20.	5/22/2014
2PB00002*HD	May 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.8	14.15	5/1/2014
2PB00002*HD	May 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	7.1	8.52231	5/1/2014
2PB00002*HD	May 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.8	9.42	5/8/2014
2PB00002*HD	May 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	7.1	12.4386	5/8/2014
2PB00002*HD	May 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.8	11.25	5/15/2014
2PB00002*HD	May 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	7.1	8.7672	5/15/2014
2PB00002*HD	May 2014	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.2	12.5925	5/1/2014
2PB00002*HD	May 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.8	15.55	5/22/2014
2PB00002*HD	May 2014	001	00610	Nitrogen, Ammonia (NH3)	30D Qty	4.7	9.51729	5/1/2014
2PB00002*HD	May 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Qty	7.1	8.341	5/22/2014
2PB00002*HD	May 2014	001	31648	E. coli	7D Conc	362	2500.	5/1/2014
2PB00002*HD	May 2014	001	31648	E. coli	7D Conc	362	2420.	5/8/2014
2PB00002*HD	May 2014	001	31648	E. coli	7D Conc	362	2420.	5/15/2014
2PB00002*HD	May 2014	001	31648	E. coli	30D Conc	161	2439.75	5/1/2014
2PB00002*HD	May 2014	001	31648	E. coli	7D Conc	362	2420.	5/22/2014
2PB00002*HD	May 2014	001	80082	CBOD 5 day	7D Conc	15.0	18.5	5/1/2014
2PB00002*HD	May 2014	001	80082	CBOD 5 day	7D Conc	15.0	22.	5/8/2014
2PB00002*HD	May 2014	001	80082	CBOD 5 day	7D Conc	15.0	24.5	5/15/2014
2PB00002*HD	May 2014	001	80082	CBOD 5 day	30D Conc	10.0	24.625	5/1/2014
2PB00002*HD	May 2014	001	80082	CBOD 5 day	7D Conc	15.0	33.5	5/22/2014
2PB00002*HD	June 2014	001	00530	Total Suspended Solids	7D Conc	18.0	30.	6/1/2014
2PB00002*HD	June 2014	001	00530	Total Suspended Solids	7D Conc	18.0	56.5	6/8/2014
2PB00002*HD	June 2014	001	00530	Total Suspended Solids	7D Conc	18.0	28.	6/15/2014
2PB00002*HD	June 2014	001	00530	Total Suspended Solids	30D Conc	12.0	36.	6/1/2014
2PB00002*HD	June 2014	001	00530	Total Suspended Solids	7D Conc	18.0	29.5	6/22/2014
2PB00002*HD	June 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.8	12.4	6/1/2014
2PB00002*HD	June 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.8	2.47	6/8/2014
2PB00002*HD	June 2014	001	00610	Nitrogen, Ammonia (NH3)	7D Conc	1.8	2.295	6/15/2014
2PB00002*HD	June 2014	001	00610	Nitrogen, Ammonia (NH3)	30D Conc	1.2	4.4375	6/1/2014
2PB00002*HD	June 2014	001	31648	E. coli	7D Conc	362	817.	6/1/2014
2PB00002*HD	June 2014	001	31648	E. coli	7D Conc	362	863.342	6/8/2014
2PB00002*HD	June 2014	001	31648	E. coli	30D Conc	161	784.559	6/1/2014
2PB00002*HD	June 2014	001	31648	E. coli	7D Conc	362	2420.	6/22/2014
2PB00002*HD	June 2014	001	80082	CBOD 5 day	7D Conc	15.0	17.3	6/8/2014
2PB00002*HD	June 2014	001	80082	CBOD 5 day	30D Conc	10.0	11.45	6/1/2014